

# WSPCert Certificate

**No. BAC-0029-02**

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5:2007 Amd 1:2009. The attested conformance refers to the, BACnet Inter-operability Building Blocks (BIBBs) listed in the annex of this certificate.

The BACnet Application Specific Controller (B-ASC)  
**TROXNETCOM Communication Controller**

with the software version:

**1.0.0.6**

of

**TROX GmbH**

Heinrich-Trox-Platz, 47504 Neukirchen-Vluyn, Germany

has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 5.0 and the Certification Rules of the BACnet Interest Group Europe, see **WSPLab Test Report No. 10.61.TRO.001**.

The certificate is valid  
until 2012/04/01

Empowered by



WSPCert is accredited by  
DAP GmbH according to EN 45011



2011/03/31

date of issuing

A handwritten signature in black ink, appearing to be "G. Weinmann".

Dipl.-Ing. G. Weinmann  
Head of Certification Body

## Annex to Certificate No. BAC-0029-02

The certification of the BACnet Implementation

### **TROXNETCOM Communication Controller of TROX GmbH**

refers to the BACnet Interoperability Building Blocks (BIBBs) listed below. BIBBs other than listed are not part of the certification.

<b>BACnet Interoperability Building Blocks</b>	
DS-RP-B	Data Sharing – Read Property – B
DS-RPM-B	Data Sharing – Read Property Multiple – B
DS-WP-B	Data Sharing – Write Property – B
DS-COV-B	Data Sharing – Change Of Value – B
DM-DDB-B	Device Management – Dynamic Device Binding – B
DM-DOB-B	Device Management – Dynamic Object Binding – B
DM-DCC-B	Device Management – Device Communication Control – B
DM-TS-B	Device Management – Time Synchronisation – B
DM-UTC-B	Device Management – UTC Time Synchronisation – B
DM-RD-B	Device Management – Reinitialize Device – B